

Installation, Operation & Maintenance Manual

End Suction Centrifugal Pumps





IMPORTANT! - Read all instructions in this manual before operating or servicing a pump.

Last update: MAR/11/2024

Before installation, read the following instructions carefully. Failure to follow instruction and safety information could cause serious bodily injury, death and/or property damage. Each Barmesa product is carefully inspected to insure proper performance. Closely following these instructions will eliminate potential operating problems, assuring years of trouble-free service.

▲ DANGER Indicates an imminently hazardous situation which, if not avoided, WILL result in death or serious iniurv.

⚠ WARNING Indicates an imminenty hazardous situation which, if not avoided, MAY result in death or serious injury.

△ CAUTION Indicates a potentially hazardous situation which, if not avoided, MAY result in minor or moderate injury.

IMPORTANT! - Barmesa Pumps is not responsible for losses, injury or death resulting from failure to observe these safety precautions, misuse, abuse or misapplication of pumps or equipment.



ALL RETURNED PRODUCTS MUST BE CLEANED, SANITIZED, OR

DECONTAMINATED PRIOR TO SHIPMENT, TO INSURE EMPLOYEES WILL NOT BE **EXPOSED TO HEALTH HAZARDS IN** HANDLING SAID MATERIAL. ALL APPLICABLE LAWS AND REGULATIONS SHALL APPLY.

△ WARNING Installation, wiring, and iunction connections must be in accordance with the National Electric Code and all applicable state and local codes. Requirements may vary depending on usage and location.

△ WARNING Installation and servicing is to be conducted by qualified personnel only.



Keep clear of suction and discharge openings. Do not insert fingers in pump with

power connected; the impeller can cause serious injury.



Always wear eye protection when working on pumps. Do not wear loose clothing that

may become entangled in moving



⚠ DANGER Pumps build up heat and pressure during operation. Allow time for pumps to cool

before handling or servicing the pump or any accessory items associated with or near the pump. Do not block or restrict the discharge pipe/hose.

MARNING Donot pump hazardous materials (flammable, caustic, etc.) or use these pumps in water over 160 °F. Do not exceed manufacturers recommended maximum performance, as this could cause the motor to overheat.

△ DANGER This pump is not intended for use in swimming pools or water installations where there is

human contact with pumped fluid.

△ DANGER Risk of electric shock. To reduce risk of electric shock, always disconnect pump from power source before

handling any aspect of the pumping system. Lock out power and tag.

▲ DANGER Do not lift, carry or hang pump by the electrical cables. Damage to the 」electrical cables can cause

shock, burns or death. Never handle connected power cords with wet hands. Use appropriate lifting device.

△ DANGER Failure to permanently ground the pump, motor and controls before connecting to power can cause shock, burns or death.

△ WARNING If engine driven, never operate in an enclosed building or area where exhaust gases can

accumulate, or near a building where gases can seep inside; always take provisions for adecuate ventilation.

⚠ **WARNING Do not** breathe exhaust fumes when working in the area of the engine. (Exhaust gases are odorless and deadly poison.)

⚠ WARNING Never add fuel to the tank while the engine is running. Stop engine and allow to cool.

Do not smoke while refueling the engine. Do not refuel near open flame.

△ WARNING Carefully read instruction manuals supplied with motor or engine before operating or servicing.

IMPORTANT! - Prior to installation. record Model Number, Serial, Amps, Voltage, Phase and HP from pump name plate for the future reference. Also record the Voltage and Current Readings at Startup:

1 Phase	Models
Amps:	Volts:
3 Phase	Models
Amps L1-2:	Volts L1-2:
Amps L2-3:	Volts L2-3:
Amps L3-1:	Volts L3-1:

Model Numb	er:	 	
Serial:		 	
Phase:	HP:		

SUCTION: 1½"-8" NPT or flange horizontal DISCHARGE: 1"-6" NPT or flange vertical

LIQUID TEMPERATURE: 160 °F (71 °C) max.

VOLUTE: Cast iron ASTM A-48 class 30 **INTERMEDIATE COUPLING:** Cast iron ASTM A-48 class 30

IMPELLER: Cast iron ASTM A-48 class 30 or stainless steel 304. Investment casting, dynamically

balanced.

SEAL: Mechanical, type 01. Ceramic stationary part, carbon ring seal and exclusion in the

rotating part. Buna-N elastomer and stainless steel spring.

SHAFT SLEEVE: Stainless steel
O-RINGS: Buna-N


MOTOR: High quality premium efficiency TEFC electric motors, 1 & 3 phases, 60 Hz, NEMA,

with rated output from 2 up to 125 HP, 1750 & 3500 RPM and frame sizes from 182 JM

to 405 JM.

HARDWARE: Carbon steel

PAINT: Air dry enamel, water based.



North America: 866 777 6060

▶ Receiving inspection

Upon receiving the pump, it should be inspected for damage or shortages. If damage has occurred, file a claim immediately with the company that delivered the pump. If the manual is removed from the packaging, do not lose or misplace.

▶ Storage

Any product that is stored for a period longer than six (6) months from the date of purchase should be bench tested prior to installation. A bench test consists of, checking the impeller to assure it is free turning and a run test to assure the motor (and switch if provided) operate properly.

At any time exceeding six (6) months, but no more than twenty four (24), the equipment must be stored in a controlled area, keeping it away from contact with rain, dust, etc., and the temperature is maintained between 43-104 °F. If there is a possibility of high humidity (coastlines, etc.), the entire unit must be sprayed with antioxidant liquid.

▶ Service Stations

To find the nearest Barmesa Pumps authorized service shop, please directly contact your distributor or the factory.

▶ Installation

The pump should be as close as possible to the liquid to be pumped, with a minimum number of couplings, adapters, etc., in order to reduce friction on the suction side.

The suction and discharge piping must be perfectly aligned in the pump volute and supported independently using support or anchors, this to prevent excessive load on the volute.

The anchors of the motor are to be anchor, on a raised base, approximately 4", this to prevent accumulated water from entering the motor.

**See friction table in pipes and fittings to determine the dimensions of the suction and discharge. (Page 8)


▶ Suction

Use pipe or hose reinforced sufficiently robust to prevent collapsing by the difference in atmospheric pressure. Check for leaks at all joints.

A successful operation depends on the calculation of the friction loss in the suction, considering acceptable limits. The minimum suction pipe size to use can be determined by comparing the NPSH available at the pump suction against the NPSH required by the impeller, as shown in the performance curves.

Usually, we recommend using a pipe diameter of 1/2" to 1" greater as that of the suction volute or body.

A strainer or sieve should be installed in the suction to prevent the entry of objects. The strainer must have a free entry area at least three times the pipe diameter. Usually a suction valve is combined with a strainer Figure 1.



3

Table 1

Friction in meters x 100 m of piping.


LITERS					PIPIN	IG DIAN	METER	-				GALLONS
PER												PER
MINUTE	1"	11/4"	11/2"	2"	2 1/2"	3"	4"	5"	6"	8"	10"	MINUTE
30	4.54							l I				8
37	6.86	1.77										10
45	9.62	2.48										12
57	16.2	4	1.53									15
68	20.6	5.22	2.42									18
76	25.1	6.34	2.94									20
95	38.7	9.6	4.48	1.2	0.54							25
113	54.6	13.6	6.26	1.82	0.75							30
151	95	23.5	10.79	3.1	1.28							40
170	119	29.4	13.45	3.85	1.6							45
189						0.66						
208	146	36 43.2	16.4 19.7	4.67 5.51	1.94 2.33	0.00						50 55
227		51 59.6	23.2	6.59	2.72 3.17	0.92						60
246			27.1	7.7		1.07						
265		68.8	31.3	8.86	3.63	1.22						70
284		78.7	35.8	10.15	4.14	1.39						75
303		89.2	40.5	11.4	4.66	1.57						80
322		100	45.6	12.6	5.27	1.77						85
360		125	56.5	15.8	6.49	2.18	0.57					95
378		138	62.2	17.4	7.11	2.39	0.62					100
416			75.25	21.05	8.55	2.88	0.75					110
454			88.3	24.7	10	3.37	0.88					120
530			119	33.2	13.5	4.51	1.17	0.38				140
568			137.5	38.1	15.45	5.16	1.33	0.43				150
605			156	43	17.4	5.81	1.49	0.48				160
643				48.55	19.65	6.54	1.67	0.54				170
681	//	3		54.1	21.9	7.28	1.86	0.6				180
757		100		66.3	26.7	8.9	2.27	0.73	0.3			200
833			OF	80	32.2	10.07	2.72	0.87	0.35			220
908				95	38.1	12.6	3.21	1.03	0.41			240
984				111	44.5	14.7	3.74	1.2	0.48			260
1060				128	51.3	16.9	4.3	1.38	0.56			280
1135				146	58.5	19.2	4.89	1.58	0.63			300
1324			1		79.2	26.1	6.55	2.11	0.85			350
1514					103	33.9	8.47	2.72	1.09	0.27		400
1892						52.5	13	4.16	1.66	0.42		500
2082						63.2	15.7	4.94	2	0.5		550
2271						74.8	18.6	5.88	2.34	0.59	0.19	600
2649						101	25	7.93	3.13	0.79	0.25	700
2838					NE		28.7	9.07	3.59	0.91	0.29	750
3028							32.4	10.22	4.04	1.02	0.32	800
3217					/		36.6	11.56	4.5	1.13	0.36	850
3406							40.8	12.9	5.05	1.27	0.41	900
3595							45.5	14.35	5.61	1.42	0.45	950
3785							50.2	15.8	6.17	1.56	0.5	1000
4163								19.15	7.41	1.87	0.6	1100
4542								22.5	8.76	2.2	0.7	1200
4920								26.45	10.2	2.56	0.81	1300
		:	ما مد ما	1	t = f:	-+:	اء اء ءا					s smooth

NOTE: The values in this table refer to frictions and clean water pipes and hoses smooth walls. As used pipe and / or hose rough walls increase the values about 50% to 100%.

Table 1 Equivalent length in meters of straight pipe and valve connections for calculating friction.

DART	DESCRIPTION				DI	AMET	ER			
PART	DESCRIPTION	1"	11⁄4"	11/2"	2"	2 1/2"	3"	4"	5"	6"
	STANDARD 90° ELBOW	0.84	1.07	1.22	1.68	1.98	2.44	3.35	4.12	4.88
	MEDIUM RADIUS ELBOW 90°	0.69	0.92	1.07	1.37	1.68	2.14	2.75	3.51	4.27
	LONG RADIUS ELBOW 90°	0.54	0.69	0.84	1.07	1.37	1.6	2.14	2.75	3.36
	STANDARD 45° ELBOW	0.38	0.54	0.61	0.77	0.92	1.15	1.53	1.83	2.29
	STANDARD TEE	1.68	2.29	2.75	3.36	4.28	5.19	6.71	8.23	10.1
	ANGLE GLOBE VALVE (OPEN)	3.97	5.49	6.71	8.23	10.7	12.2	16.8	21.3	25.9
	GLOBE VALVE (OPEN)	7.93	10.7	13	16.8	21.3	24.4	35.1	42.7	48.8
	GATE VALVE (OPEN)	0.19	0.25	0.29	0.38	0.43	0.54	0.69	0.84	1.07
	INCREASER	1.21	1.52	1.82	2.74	3.35	4.26	6.09	7.92	10.1
	REDUCER	0.3	0.3	0.3	0.61	0.61	0.9	1.21	1.21	2.13
	SUCTION VALVE	0.91	1.21	1.52	2.13	2.74	3.35	4.87	6.4	7.92

Figure 2 Wrong installation.




Suction height - suction pipe should have a slope of 0.39" per 3.3 ft of suction. Never exceed 16.4 ft suction, considering friction. (*Figure 3*)

Correct

0.39" of inclination per 3.28 ft

Inclination.

Figure 3




Positive/Drowned Suction - A gate valve is installed in the suction pipe to service the pump (*Figure 4*). Volute or body have plugs, and these must be removed to allow trapped air to escape.

Figure 4 Positive suction. Correct Check valve (completely open) "D" 6 "D" min.

SPRINGER PARTS

Figure 5 Positive suction.

Incorrect





▶ Discharge pipe

Use pipe or hose reinforced sufficiently robust to prevent destruction due to high pressure.

Due to the cost of energy or BHP necessary to overcome the friction generated by using a smaller diameter pipe, a larger diameter discharge pipe is commonly used than the required by the volute or body.

Figure 6 Discharge piping.





In order to determine the optimal size of the piping, compare the total cost of the equipment's operation (cost of the pump, control piping and equipment, energy consumption). By increasing the discharge diameter reasonably, it reduces the required BHP due to the low friction. Perform different tests using several piping diameters until you find the more convenient.

The pipe, valves, etc. should be perfectly align with the volutes suction and discharge centerlines, this to avoid any excessive loads on the pumps volute. If needed, install new expansive joints to protect the pump from excessive thermal or pressure forces.

▶ Pre-Operation

 Check Voltage and Phase -Compare the voltage and phase information stamped on the pump name plate. Check Pump Rotation - Improper motor rotation can result in poor pump performance and can damage the motor and/or pump. Check rotation on three phase units by momentarily applying power and observe the "kickback".



Kickback should always be in a counter-clockwise direction as viewed from motor end or opposite to impeller rotation. Impeller rotation is counter-clockwise as viewed from bottom of pump.

3. **Name Plate** - Record the information from the pump name plate to drawing in front of manual for future reference.

4. **Priming** - Every centrifugal pump must be primed (suction pipe and pump's body should have liquid), before operating.

Install the foot valve at the suction pipe *Figure 1* and fill with liquid the superior part of the pump's body. Sometimes air is trapped inside the body, to remove it you should uncap the male plug until the liquids spills out. Re-install the male plug using a sealant.



IMPORTANT! - Do not operate pump without priming first. Operating dry will damage seal.

▶ Starting

When starting for the first time your equipment check that the discharge valve is 90% closed. Gradually open the valve until the motor runs at full load (amperage plate). Never allow the amperage consumed by the pump exceeds the maximum permitted by the engine.

▶ Mechanical seal

Mechanical seals installed in this pumps are lubricated by water, there for the pump should not be operated dry. You will find the appropriate seal for each use and liquid to be pumped, check with your Barmesa Pumps distributor for more information.

▶ Stuffing box*

If the pump has graphite packing (stuffing box) consider the following:

- When the pump is placed into operation, the liquid will drip from the stuffing box; if this does not happen, loosen the nuts on the stuffing box until dripping occurs.
- After a few minutes of operation, gradually tighten the nuts until the drip decreases but does not stop.
- Once the pump has operated for a reasonable period and the dripping has not decreased to "a few drops per minute", it is necessary to tighten the nuts stuffing box. If tightening the nuts the required drip is not achieved, the graphite packing rings must be replaced.

▶ Frame*

All pumps come with factory lubricated bearings. It is very important to have oil in the oil tank. (Use oil DTE26). Change the oil every 1,000 hours of operation, considering a daily operation of 8 hours.

It is important not to overfill the oil tank because it would cause an increase in pressure by heating, affecting the bearings and seals. In normal operation, the frame temperature increases 122 °F above ambient temperature.

▶ Flexible coupling*

All pumps operated through flexible coupling or by pulleys and belts must be perfectly aligned to ensure smooth operation. In no case occur problems with flexible couplings if the pump-motor alignment is correct. All pumps are manufactured following condition.

*For Barmesa pumps with universal transmission.



IMPORTANT! - Always unplug the pump before applying maintenance, service or repair to avoid electric shock.

▶ Maintenance

Body and Impeller - All pump parts are removable by removing nuts and For bolts. body maintenance, disconnect the suction and discharge, and remove the body of the intermediate coupling. For maintenance of the impeller is not necessary to remove the suction or discharge, simply remove the body nuts; this would uncover the impeller. Examine and replace if it shows wear or damage.

When the impeller requires replacement, remove the screw of the shaft, and using a puller, remove the impeller being careful not to abuse the keyway of the shaft.

Mechanical Seal - To inspect or replace the shaft seal, remove the body and impeller. If any part shows wear or damage, replace both parts (stationary seat and rotary part). The rotating seal parts may be stuck together with the shaft, this happens when the seal has been assembled for a long time.

If the mechanical seal does not leak and there is need to open the pump for inspection or cleaning, *DO NOT* remove the seal, remove the spring only if the impeller needs to be removed. Once a seal has been in operation is very difficult to remove and reassembly without creating a seal leak.

▶ Disassembly

Mechanical Seal - Perform the steps above. Remove the rotating part. It may be necessary to remove the intermediate link to remove the stationary seat. To do this, remove the nuts and washers that attach the coupling to the motor. When removing the coupling, the steady part will move towards the front seat of the shaft and the sleeve. If the seat does not yield itself, push from the rear of the coupling.



Handle seal parts with extreme care. DO NOT damage lapped surfaces.

▶ Reassembly

Mechanical Seal - Identify all parts of *Figures 7* and 8. The ring (6) and seat (1) are perfectly polished, so care must be taken not to scratch or smudge. The cleaning during the assembly process is very important.



IMPORTANT! - All parts must be clean before reassembly.

Step 1: Install the intermediate coupling if it was previously removed. Make sure the shaft and cavities, where will it seats, are clean. The shaft sleeve should not be sharp, but a radius of about 1/32". It is recommended that lightly polish the area of the shaft. If the shaft and it radius are perfectly polished, the seal can be relatively easily installed.

Step 2: Install the seat assembly (1 and 2) on the inside of the intermediate coupling, slightly moistening with water on the rubber parts (do not use grease or oil). This assembly should be done only manually, meaning without the use of an instrument.

Step 3: Install the rotating portion of the seal without the spring. Moisten the arrow and the inside of the seal with some water (do not use grease or oil). With clean, dry hands, insert the rotating portion to the shaft, sliding it abuts the stationary seat. Once the seal is in place, insert the spring (5).

Step 4: Place the impeller and washers; tighten the hex screw.

Figure 7 | Mech

Mechanical Seal - Sectional View.

- 1 Ceramic seat
- 2 Seal seat Buna-N
- 3 Inox. retainer
- 4 Inox. jacket
- 5 Inox. spring
- 6 Carbon ring
- 7 Elastomer Buna-N
- 8 Inox. washer







Figure 8 Mechanical Seal - Assembly.












MODEL	CODE	HP	RPM	FASE	FRAME	Α	В	С	D	Ε	F	G
IA1-3-2	62212007	3	3540	1	182JM	4.50	6.72	7.50	5.50	3.50	12.34	0.41
IA1-3-2	62212003	3	3540	3	143/5JM	3.50	5.88	5.50	5.00	2.59	11.41	0.34
IA1-5-2	62212008	5	3525	1	184JM	4.50	6.72	7.50	5.50	3.50	14.34	0.41
IA1-5-2	62212003	5	3525	3	182/4JM	4.50	7.56	7.50	5.50	2.75	13.14	0.41
IA1-7.5-2	62212009	7.5	3535	1	213JM	5.25	8.04	8.50	7.00	4.25	16.09	0.41
IA1-7.5-2	62212004	7.5	3535	3	213/5JM	5.25	8.60	8.50	7.00	3.50	15.88	0.41


ALL DIMENSIONS ARE IN INCHES.



MODEL	CODE	HP	RPM	PHASE	FRAME	Α	В	С	D	Ε	F	G	Н
IA1-1/2-5-2	62212011	5	3500	3	182/4JM	4.50	7.56	7.50	5.50	2.75	13.15	4.27	0.41
IA1-1/2-5-2	62212018	5	3500	1	184JM	4.50	6.72	7.50	5.50	3.50	14.34	4.27	0.43
IA1-1/2-7.5-2	62212012	7.5	3500	3	182/4JM	4.50	8.60	7.50	5.50	2.75	13.15	4.27	0.41
IA1-1/2-7.5-2	62212019	7.5	3500	1	213JM	5.25	8.04	8.50	7.00	4.25	16.09	4.27	0.43
IA1-1/2-10-2	62212013	10	3500	3	213/5JM	5.25	8.60	8.50	7.00	3.25	15.89	4.54	0.41
IA1-1/2-15-2	62212014	15	3500	3	213/5JM	5.25	8.60	8.50	7.00	3.25	15.89	4.54	0.41
IA1-1/2-20-2	62212015	20	3500	3	254/6JM	6.25	10.50	10.0	10.0	4.00	20.72	5.28	0.53
IA1-1/2H-3-4	62212021	3	1750	3	182/4JM	4.50	7.56	7.50	5.50	2.75	13.15	4.40	0.41
IA1-1/2H-15-	2 62212025	15	3500	3	213/5JM	5.25	8.60	8.50	7.00	3.25	15.88	4.53	0.41
IA1-1/2H-20-	2 62212026	20	3500	3	254/6JM	6.25	10.50	10.0	10.0	4.00	20.72	5.40	0.53
IA1-1/2H-25-	2 62212027	25	3500	3	284/6JM	7.00	11.0	11.0	11.0	4.50	23.12	5.40	0.53
IA1-1/2H-30-	2 62212028	30	3500	3	284/6JM	7.00	11.0	11.0	11.0	4.50	23.12	5.40	0.53

ALL DIMENSIONS ARE IN INCHES.


GENERAL DIMENSIONS IA11/2XH MODEL



MODEL	CODE	HP	RPM	PHASE	FRAME	Α	В	С	D	Ε	F	G
*IA1½HX-3-4	62212031	3	1750	3	182/4TCZ	4.50	7.56	7.50	5.50	2.75	13.12	0.41
*IA1½HX-5-4	62212033	5	1750	3	182/4TCZ	4.50	7.56	7.50	5.50	2.75	13.12	0.41
*IA1½HX-15-2	62212036	15	3500	3	213/5JM	5.25	8.60	8.50	7.00	3.25	15.88	0.41
IA1½HX-20-2	62212037	20	3500	3	254/6JM	6.25	10.48	10.00	10.00	4.00	20.73	0.53
IA1½HX-25-2	62212038	25	3500	3	284/6JM	7.00	11.07	11.00	11.00	4.50	23.05	0.53
IA1½HX-30-2	62212039	25	3500	3	284/6JM	7.00	11.07	11.00	11.00	4.50	23.05	0.53

ALL DIMENSIONS ARE IN INCHES WITH 254JM SHAFT EXTENSION


GENERAL DIMENSIONS IA2 & IA2H MODELS




MODEL	CODE	HP	RPM	PHASE	FRAME	Α	В	С	D	E	F	G	Н
IA2-10-2	62212045	10	3500	3	213/5JM	5 25	8 67	8 50	7 00	3 25	15.89	153	0.41
IA2-15-2	62212046	15	3500	3	ZIJ/JUM								
IA2-20-2	62212047	20	3500	3	254/6JM	6.25	10.48	10.00	10.00	4.00	20.73	5.28	0.53
IA2-25-2	62212048	25	3500	3	284/6JM	7.00	11.07	11.00	11.00	4.50	23.05	5.22	0.55
IA2H-25-2	62212056	25	3500		284/6JM	7.00	11 07	11.00	11.00	4 50	23.05	E 7.4	0 E Z
IA2H-30-2	62212057	30	3500	3	284/6JM	7.00	11.07	11.00	11.00	4.30	23.03	5.54	0.55

ALL DIMENSIONS ARE IN INCHES

GENERAL DIMENSIONS IA2HH MODEL



DIMENSIONS IN INCHES




*WITH 284/6 JM SHAFT EXTENSION. ALLL DIMENSIONS ARE IN INCHES

UPDATE: 09/11/2023

North America: 866 777 6060


GENERAL DIMENSIONS IA21/2 MODEL



MODEL	CODE	HP	RPM	PHASE	FRAME	Α	В	С	D	Е	F	G	Н
IA2-1/2-3-4	62212091	3	1750	3	182/4JM	4.50	7.54	7.50	5.50	2.75	13.15	4.47	0.41
IA2-1/2-5-4	62212093	5	1750	3	182/4JM	4.50	7.54	7.50	5.50	2.75	13.15	4.47	0.41
IA2-1/2-10-2	62212094	10	3500	3	213/5JM	5.25	8.67	8.50	7.00	3.25	15.89	4.72	0.41
IA2-1/2-15-2	62212095	15	3500	3	213/5JM	5.25	8.67	8.50	7.00	3.25	15.89	4.72	0.41
IA2-1/2-20-2	62212096	20	3500	3	254/6JM	6.25	10.48	10.00	10.00	4.00	20.73	5.47	0.53
IA2-1/2-25-2	62212097	25	3500	3	284/6JM	7.00	11.07	11.00	11.00	4.50	23.05	5.40	0.53
IA2-1/2-30-2	62212098	30	3500	3	284/6JM	7.00	11.07	11.00	11.00	4.50	23.05	5.40	0.53
IA2-1/2-40-2	62212099	40	3500	3	324/6JM	8.00	12.57	12.50	12.00	5.00	25.59	5.40	0.66

ALL DIMENSIONS ARE IN INCHES


GENERAL DIMENSIONS IA21/BJM MODEL



MODEL	CODE	HP	RPM	PHASE	FRAME	Α	В	С	D	Е	F	G
IA2.1/2BJM-15-4	62212116	15	1750	3	254/6JM 254/6JM	6 25	10 40	10 00	10.00	4 00	20.27	
IA2.1/2BJM-20-4	62212117	20	1750	3	254/6JM	0.25	10.40	10.00	10.00	4.00	20.27	0.53
IA2.1/2BJM-25-4	62212118	25	1750	3	284/6JM	7.00	10.01	11 00	11 00	4 50	23.05	
IA2.1/2BJM-30-4	62212119	30	1750	3	284/6JM	7.00	10.91	11.00	11.00	4.50	23.03	

ALL DIMENSIONS ARE IN INCHES.

GENERAL DIMENSIONS IA21/2H MODEL



MODEL	CODE	H.P.	RPM	FRAME	Α	В	С	D	Е	F	GØ
IA2-1/2H-40-2	62212105		3500	324/6JM	8 00"	12 57"	12 50"	12 00"	5.00"	25 50"	
IA2-1/2H-50-2	62212106	50	3500	324/ 6JM	0.00	12.57	12.50	12.00	5.00		0.66"
IA2-1/2H-60-2	62212107		3500	364/5JM	0.00"	16 00"	14.00"	12 25"	5 6 7 "		
IA2-1/2H-75-2	62212108	75	3500	304/3JM	9.00	16.02	14.00	12.23	5.65	27.55	
IA2-1/2H-100-2	62212109	100	3500	405TC Z	10.00"	18.09"	16.00"	13.75"	6.62"	31.52"	0.81"

DIMENSIONS IN INCHES

SPRINGER PARTS

GENERAL DIMENSIONS IA3 / IA3H MODELS DISCHARGE 3" NPT THREADED \bigcirc SUCTION 4" NPT -THREADED 7.13 6.75 С D H Ø 4 HOLES MODEL PART No. HP RPM PHASE FRAME С D Ε F Н В G IA3-3-4 62212121 3 1750 3 182/4JM 4.50 7.54 7.50 5.50 2.75 13.15 4.47 182/4JM IA3-5-4 62212122 5 1750 3 0.41 IA3-7.5-4 62212123 7.5 1750 213/5JM 7.00 15.89 4.72 5.25 8.67 8.50 3.25 213/5JM IA3-15-2 62212126 15 3500 3 62212127 20 IA3-20-2 3500 3 254/6JM 6.25 10.48 10.00 10.00 4.00 20.73 IA3-25-2 62212128 25 3500 3 284/6JM 7.00 11.07 11.00 11.00 4.50 23.05 0.53 IA3-30-2 62212121 30 3500 284/6JM 3 5.40 IA3-40-2 62212130 40 3500 324/6JM 3 8.00 25.53 12.57 12.50 12.00 5.00 0.66 IA3-50-2 62212131 50 3500 324/6JM 3 IA3H-30-2 62212135 30 3500 284/6JM 7.00 0.53 11.07 11.00 11.00 4.50 23.05 IA3H-40-2 62212136 40 3500 324/6JM 8.00 12.57 12.50 12.00 5.00 25.53

324/6JM

364/5JM

364/5JM

9.00

16.02

3500

3

3

15

IA3H-50-2 62212137 50

IA3H-60-2 62212138 60 3500

IA3H-75-2 62212139 75 3500

ALL DIMENSIONS ARE IN INCHES


14.00

12.25 5.63 27.53

5.40

0.66


GENERAL DIMENSIONS IA3BJM MODEL



MODEL	CODE	HP	RPM	PHASE	FRAME	Α	В	С	D	E	F	G
IA3BJM-15-4	62212145	15	1750	3	254/6JM	6 25	10.49	10.00	10.00	4.00	20.27	
IA3BJM-20-4	62212146	20	1750	3	254/6JM	0.23	10.40	10.00	10.00	4.00	20.27	0.53
IA3BJM-25-4	62212147	25	1750	3	284/6JM	7.00	10.01	11.00	11.00	4.50	23.05	
IA3BJM-30-4	62212148	30	1750	3	284/6JM	7.00	10.91	11.00	11.00	4.50	23.03	
IA3BJM-40-4	62212149	40	1750	3	324/6JM	8.00	12.56	12.50	12.00	5.00	25.55	0.66


DIMENSIONS IN INCHES


GENERAL DIMENSIONS IA4 MODEL




MODEL	НР	RPM	PHASE	FRAME	Α	В	C	D	E	F	G
IA4-40-2	40	3530	3	324TSC	24"	10.5"	5"	12.5"	8"	12"	0.66"
IA4-50-2	50	3530	3	326TSC	25.5"	12"	,	12.5	0	12	0.00
IA4-60-2	60	3565	3	364TSC	28"	11.25"	5.75"	14"	9"	16.5"	0.66"
IA4-75-2	75	3555	3	365TSC	29"	12.25"	5.75	14	9	10.5	0.00
IA4-100-2	100	3560	3	405TSC	30.5"	13.75"	6.38"	16"	10"	18.75"	0.81"
IA4-125-2	125	3570	3	444TSC	37.75"	14.5"	8.75"	18"	11"	10.75	0.01

GENERAL DIMENSIONS IA4-7.5-4 MODEL






GENERAL DIMENSIONS IA4-10-4 MODEL




North America: 866 777 6060


Int'l: +1 267 404 2910



GENERAL DIMENSIONS IA4-15-4 MODEL









MODEL	HP	RPM	PHASE	FRAME	Α	В	C	D	E	F
IA4BJH-20-4	20	1745	3	256JM	20.25"	10"	4.25"	10"	6.25"	9.9"
IA4BJH-25-4	25	1760	3	284JM	22.62"	9.5"	4.75"	11"	7"	12.94"
IA4BJH-30-4	30	1760	3	286JM	24.56"	11"	4./3	''	′	12.94
IA4BJH-40-4	40	1765	3	324JM	25.31"	10.5"	5.25"	12.5"	8"	15.44"
IA4BJH-50-4	50	1765	3	326JM	25.31"	12"	3.23	12.3	0	13.44
IA4BJH-60-4	60	1765	3	364JM	27"	11.25"	5.88"	14"	9"	16.44"

GENERAL DIMENSIONS IA6BJM-40-4 MODEL





TYPICAL EXPLODED VIEW CENTRIFUGAL PUMP



To order any spare part please supply the model and serial number as shown on the nameplate, and the description and part number as shown in the parts list.

SPRINGER P

Item	Part no.	Description	Qty.
	40020057B	3 HP, 3500 RPM, 1 Ph, frame 182JM	
	40020008	3 HP, 3500 RPM, 3 Ph, frame 143/5JM	
1	40020059B	5 HP, 3500 RPM, 1 Ph, frame 184JM	
'	40020011	5 HP, 3500 RPM, 3 Ph, frame 182/4JM	_
	40020061B	7.5 HP, 3500 RPM, 1 Ph, frame 213JM	
	40020014	7.5 HP, 3500 RPM, 3 Ph, frame 213/5JM	
2	03010028	Intermediate Coupling, for 3 and 5 HP	1
_	03010018	Intermediate Coupling, for 7.5 HP	'
3	03090038	Volute Case	1
	03140031	Impeller IA1-3-2, Ø 5.75"	
4	03140031B	Impeller IA1-5-2, Ø 6.81"	1
	03140031C	Impeller IA1-7.5-2, Ø 7½"	
5	30400808	Shaft Sleeve	1
6	92010029J	O-Ring Shaft Sleeve	1
7	92010014	Slinger	1
8	31030131	Mechanical Seal	1
9	92010033	O-Ring	1
10	91010345C	Impeller's Screw	1
11	91010061	Lock Washer 3/8" SS	1
12	30400418	Impeller Washer	1
13	30400631	Shaft Key	1
14	91010303	Stud 3/8"-16x 1½"	8
15	91010413	Hex Nut 3/8"	8
16	91010012	Lock Washer 3/8" Steel	8
17	91010243	Cap Screw 3/8"-16 x 11/4"	4
18	91010012	Lock Washer 3/8" Steel	4
19	93010143	Pipe Plug ¼" NPT	5

North America: 866 777 6060

▶ IA1½

ltem	Part no.	Description	Qty.	
	40020011	Motor 5 HP 3500 RPM 3Ph BC 182/4JM		
	40020059B	Motor 5 HP 3500 RPM 1Ph BC 184JM		
	40020014	Motor 7½ HP 3500 RPM 3Ph BC 213/5JM		
1	40020061B	Motor 7½ HP 3500 RPM 1Ph BC 213JM	-	
	40020017	Motor 10 HP 3500 RPM 3Ph BC 213/5JM	1	
	40020020	Motor 15 HP 3500 RPM 3Ph BC 213/5JM		
	40020023	Motor 20 HP 3500 RPM 3Ph BC 254/6JM		
	03010028	Intermediate coupling for 5 and 7½ HP		
2	03010018	Intermediate coupling for 10 and 15 HP	1	
	03010051	Intermediate coupling for 20 HP		
3	03090039	Volute Case	1	
	03140032	Impeller IA1½ - 5 HP - Ø 6.75"		
	03140032B	Impeller IA1½ - 7½ HP - Ø 7.50"		
4	03140032C	Impeller IA1½ - 10 HP - Ø 8.00"	1	
	03140032D	Impeller IA1½ - 15 HP - Ø 9.00"]	
	03140032E	Impeller IA1½ - 20 HP - Ø 9.00"		
5	30400808	Shaft sleeve for 5 HP to 15 HP	1	
5	30400812	Shaft sleeve for 20 HP	1	
6	92010029M	Oring shaft sleeve for 20 HP	- 1	
0	92010029J	Oring shaft sleeve for 5 HP to 15 HP] '	
7	92010014	Slinger for 5 HP to 15 HP		
/	92010016	Slinger for 20 HP	1	
8	31030133	Mechanical seal 1.750" for 20 HP	1	
0	31030131	Mechanical seal 1.250" for 5 HP to 15 HP] '	
9	92010033	O-Ring	1	
10	91010345C	Impeller's screw	1	
11	91010061	Lock washer	1	
12	30400418	Impeller washer	1	
13	30400631	Shaft key	1	
14	91010303	Stud 3/8	8	
15	91010413	Hex nut 3/8	8	
16	91010012	Lock washer 3/8	8	
17	91010242	Cap screw 3/8 for 5 HP to 7½ HP	4	
17	91010263	Cap screw 1/2 for 10 HP to 20 HP	4	
10	91010014	Lock washer 1/2 for 10 HP to 20 HP	4	
18	91010012	Lock washer 3/8 for 5 HP to 7½ HP	4	
19	93010143	Pipe plug 1/4 npt	5	



To order any spare part please supply the model and serial number as shown on the nameplate, and the description and part number as shown in the parts list.

▶ IA11/2H

ltem	Part no.	Description	Qty.	
	40020009	3 HP,1800rpm, 3ph, frame 182T JM		
	40020020	15 HP, 3530 rpm, 3 ph, frame 213/5 JM		
1	40020023	20 HP, 3525 rpm, 3 ph, frame 256T JM	-	
	40020026	25 HP, 3530 rpm, 3 ph, frame 284T JM		
	40020029	30 HP, 3525 rpm, 3 ph, frame 286T JM		
	03010028	Intermediate Coupling, for 3 HP		
	03010018	Intermediate Coupling, for 15 HP	9.	
(2)	03010051	Intermediate Coupling, for 20 HP	- 1	
	03010020	Intermediate Coupling, for 25 & 30 HP		
3	03090039B	Volute Case	1	
	03140065G	Impeller IA11/2H-3-4, Dia. 9.00" (shaft 7/8"Ø)		
4	03140065	Impeller IA1½H-15-2, Dia. 7.94" (shaft 7/8"Ø)		
4	03140065B	Impeller IA1½H-20-2, Dia. 8.63" (shaft 1¼"Ø)	1	
	03140065C	Impeller IA11/2H-25 & 30-2, Dia. 9.00"(shaft 11/4"Ø)		
5	30400808	Shaft Sleeve, for 3 HP to 15 HP	1	
5	30400812	Shaft Sleeve, for 20 to 30 HP		
6	92010029J	O-Ring Shaft Sleeve for 3 & 15 HP		
6	92010029M	O-Ring Shaft Sleeve for 20 to 30 HP		
7	92010014	Slinger, for 3 & 15 HP	1	
'	92010016	Slinger, for 20 & 30 HP	'	
8	31030131	Mech. Seal, for 3 &15 HP	1	
0	31030133	Mech. Seal, for 20 & 30 HP		
9	92010033	O-Ring	1	
10	91010345C	Impeller's Screw, for 3 & 15 HP	1	
10	91010351	Impeller's Screw, for 20 & 30 HP	'	
11	91010061	Lock Washer, 3/8" SS, for 3 & 15 HP	1	
	91010062	Lock Washer, ½" SS, for 20 & 30 HP	'	
12	30400418	Impeller Washer, for 3 HP & 15 HP	1	
12	30400416	Impeller Washer, for 20 & 30 HP	,	
13	30400631	Shaft Key, for 3 & 15 HP	1	
	30400633	Shaft Key, for 20 & 30 HP		
14	91010303	Stud 3/8"-16 x 11/2"	8	
15	91010413	Hex Nut 3/8"	8	
16	91010012	Lock Washer 3/8"	8	
	91010243	Cap Screw, 3/8"-16 x 1" for 3 HP		
17	91010263	Cap Screw, ½"-13 x 1½" for 15 & 20 HP	4	
	91010282	Cap Screw, 5/8"-11 x 1½" for 25 & 30 HP		
	91010012	Lock Washer, 3/8" Steel, for 3 HP		
18	91010014	Lock Washer, ½" Steel, for 15 HP - 20 HP	4	
	91010015	Lock Washer, 5/8" Steel, for 25 to 30 HP	<u> </u>	
19	93010143	Pipe Plug ¼" NPT	5	

▶ IA2

ltem	Part no.	Description	Qty
	40020006	2 HP 1750 RPM 3 PH frame 143/5	
	40020017	10 HP 3500 RPM 3 PH frame 213/5	
	40020020	15 HP 3500 RPM 3 PH frame 213/5	
1	40020023	20 HP 3500 RPM 3 PH frame 254/6	-
		25 HP 3500 RPM 3 PH frame 284/6	
	40020029	30 HP 3500 RPM 3 PH frame 284/6	
	03010028	Intermediate coupling 2 HP	
2	03010018	Intermediate coupling 10 & 15 HP	
2		Intermediate coupling 20 HP	1
	03010020	Intermediate coupling 25 and 30 HP	
3		Volute Case	1
		Impeller IA2 - 2 HP - 4 Ø9.00"(shaft 7/8"Ø)	
		Impeller IA2 for 10 HP - 2 Ø7.56" (shaft 7/8"Ø)	
4		Impeller IA2 for 15 HP - 2 Ø8.31", (shaft 7/8"Ø)	1
-		Impeller IA2 for 20 - 30 HP-2 Ø9.000", (shaft 1.1/4"Ø)	
_		Shaft Sleeve for 2 to 15 HP	
5		Shaft Sleeve for 20 to 30 HP	1
		O-Ring Shaft Sleeve for 2 to 15 HP	
6		O-Ring Shaft Sleeve for 20 to 30 HP	1
		Slinger for 3-15 HP	
7		Slinger for 20-50 HP	1
		Mech. Seal, for 2 to 15 HP	
8		Mech. Seal, for 20 to 30 HP	1
9		O-Ring	1
4		Impeller's Screw 3/8 X1" SS 2 HP	
10		Impeller's Screw 3/8 X1" SS10 to15 HP	1
u		Impeller's Screw 3/8 X1" SS 20 to 30 HP	
		Lock Washer 3/8" SS 2 to 15 HP	
11		Lock Washer 1/2" SS 20 to 30 HP	1
		Impeller Washer for 2 to 15 HP	
12		Impeller Washer for 20 to 30 HP	1
		Shaft Key 3/16",for 2 to 15 HP	
13		Shaft Key 1/4", for 20 to 30 HP	1
14		Stud 3/8X1½	8
15		Hex. Nut 3/8"	8
16		Lock Washer 3/8"	8
-	91010242	Cap Screw, 3/8 x 1" for 2 HP	
17		Cap Screw, 1/2 x 1-1/2" for 10 to 20 HP	4
		Cap Screw, 5/8 x 1-1/2" for 25 to 30 HP	
		Lock Washer 3/8" for 2 HP	
18		Lock Washer 1/2" for 10 to 20 HP	4
		Lock Washer 5/8" for 25 to 30 HP	
19		Pipe Plug 1/4"	5


▶ IA2H

Item	Part. No.	Description	Qty.
1	40020026	25 HP 3500 RPM 3 Ph frame 284/6	1
'	40020029	30 HP 3500 RPM 3 Ph frame 284/6	'
2	03010020	Intermediate coupling	1
3	03090040B	Volute case	1
4	03140034H	Impeller IA2H - 25 HP Ø8.31" (shaft 1¼"Ø)	- 1
4	03140034I	Impeller IA2H - 30 HP Ø9.00" (shaft 1¼"Ø)	'
5	30400812	Shaft sleeve	1
6	92010029M	O-Ring shaft sleeve	1
7	92010016	Slinger	1
8	31030133	Mechanical seal	1
9	92010033	O-Ring	1
10	91010351	Impeller screw 1/2 X 1" SS	1
11	91010062	Lock washer 1/2" SS	1
12	30400416	Impeller washer	1
13	30400633	Shaft key 1/4"	1
14	91010303	Stud 3/8 X 1-1/2	8
15	91010413	Hex. Nut 3/8"	8
16	91010012	Lock Washer 3/8"	8
17	91010282	Cap Screw 5/8 X 1-1/2"	4
18	91010015	Lock Washer 5/8"	4
19	93010143	Pipe Plug 1/4"	5



▶ IA21/2

ltem	Part no.	Description	Qty			
	40020009	3 HP, 1750 RPM, 3 F, frame 182/4 JM				
	40020012	5 HP, 1750 RPM, 3 F, frame 182/4 JM				
	40020017	10 HP, 3500 RPM 3 F, frame 213/5 JM				
1	40020020	15 HP, 3500 RPM 3 F, frame 213/5 JM				
'	40020023	20 HP, 3500 RPM 3 F, frame 254/6 JM	_			
	40020026	25 HP, 3500 RPM 3 F, frame 284/6 JM				
	40020029	30 HP, 3500 RPM, 3 F, frame 284/6 JM				
	40020032	40 HP 3500 RPM, 3 F, frame 324/6 JM				
	03010028	Intermediate coupling, for 3 & 5 HP				
2	03010018	Intermediate coupling, for 10 & 15 HP	_			
2	03010051	Intermediate coupling, for 20 HP	1			
	03010020	Intermediate coupling, for 25 & 30 HP				
3	03090041	Volute case	1			
		Impeller IA2½ for 3 HP - Ø7.31" (shaft 7/8"Ø)				
		Impeller IA2½ for 5 HP - Ø8.38" (shaft 7/8"Ø)				
		Impeller IA2½ for 10 HP - Ø6.94" (shaft 7/8"Ø)				
	03140034	Impeller IA2½ for 15 HP - Ø6.94" (shaft 7/8"Ø)				
4	3140034B	Impeller IA2½ for 20 HP - Ø7.69" (shaft 1-1/4"Ø)	1			
		Impeller IA2½ for 25 HP - Ø8.44" (shaft 1-1/4"Ø)				
		Impeller IA2½ for 30 HP - Ø8.88" (shaft 1-1/4"Ø)				
	3140034E	Impeller IA2½ for 40 HP - Ø9.00" (shaft 1-1/4"Ø)				
	30400808	Shaft sleeve, for 3 to 15 HP				
5	30400812	Shaft sleeve, for 20 to 40 HP	1			
7	92010029J	O-Ring shaft sleeve, for 3 to 15 HP				
6		O-Ring shaft sleeve, for 20 to 40 HP	1			
	9201002311	Slinger, for 3 to 15 HP				
7	92010014	Slinger, for 20 to 40 HP	1			
	31030131	Mech. seal, for 3 to 15 HP				
8		Mech. seal, for 20 to 40 HP	1			
0	31030133		1			
9	92010033	O-Ring	1			
10		Impeller's screw, for 3 to 15 HP	1			
	91010351	Impeller's screw, for 20 to 40 HP				
11	91010061	Lock washer 3/8" SS, for 3 to 15 HP	1			
	91010062	Lock washer 1/2" SS, for 20 to 40 HP				
12	30400418	Impeller washer, for 3 to 15 HP	1			
	30400416	Impeller washer, for 20 to 40 HP				
13	30400631	shaft Key, for 3 to 15 HP	1			
		shaft Key, for 20 to 40 HP				
14	91010303	Stud 3/8" X 1-1/2"	8			
15	91010413	hex. Nut 3/8"	8			
16	91010012	Lock washer 3/8"	8			
	91010243	Cap screw 3/8 x 1-1/4" for 3 & 5 HP				
17	91010263	Cap screw 1/2 x 1-1/2" for 10 to 20 HP	4			
	91010282	Cap screw 5/8 x 1-1/2" for 25 to 40 HP				
	91010012	Lock washer 3/8" for 3 & 5 HP				
18	91010014	Lock washer 1/2" for 10 to 20 HP	4			
	91010015	Lock washer 5/8" for 25 to 40 HP				
19	93010143	Pipe Plug 1/4" NPT	5			




SPRINGER PART

To order any spare part please supply the model and serial number as shown on the nameplate, and the description and part number as shown in the parts list.

Item	Part No.	Description	Qty.
1	40020029	30 HP, 3500 RPM, 3 Ph, frame 284/6JM	1
'	40020032	40 HP, 3500 RPM, 3 Ph, frame 324/6JM	'
2	03010061	Intermediate coupling	1
3	03090093	Volute case	1
4	03140092B	Impeller IA2HH -30 HP- Ø 9.450"	1
-	03140092C	Impeller IA2HH -40 HP- Ø 9.925"	'
5	030400837	Shaft sleeve	1
6	92010029M	Shaft sleeve O-ring	1
7	92010016	Slinger	1
8	31030133	Mechanical seal	1
9	92010089	O-ring	1
10	91010351	Impeller cap screw 1/2 x 1-1/2" SS	1
11	91010062	Lock washer 1/2" SS	1
12	30400416	Impeller washer	1
13	30400633	Shaft key	1
14	91010310	Stud 1/2 x 2"	6
15	91010415	Hex nut 1/2"	6
16	91010014	Lock washer 1/2"	6
17	91010282	Cap screw 5/8" x 1-1/2"	4
18	91010015	Lock washer 5/8"	4
19	30400328	Wear ring	1
20a	93010142	Pipe plug 1/2"	1
20b	93010143	Pipe plug 1/4"	3

North America: 866 777 6060



To order any spare part please supply the model and serial number as shown on the nameplate, and the description and part number as shown in the parts list.

4

8

1

1

1

1

4

24

28

91010416

31010008

30400316

26 03190010B Wear plate

27 92010191 Wear plate gasket

93010142 Pipe plug 1/2'

Hex nut 5/8"

Retaining ring

Wear ring

91010283 Cap screw 5/8" x 2"

North America: 866 777 6060

▶ IA3

la e ···	Dout N.	Desertination	0+	
Item	Part. No.	Description	Qty.	
	40020009	3 HP 1750 RPM 3Ph, frame 182/4 JM		
	40020012	5 HP 1750 RPM 3Ph, frame182/4		
	40020015	7.5 HP 1750 RPM 3Ph, frame 213/5		
	40020020	15 HP 3500 RPM 3Ph, frame 213/5	-	
1	40020023	20 HP 3500 RPM 3Ph, frame 254/6		
	40020026	25 HP 3500 RPM 3Ph, frame 284/6		
	40020029	30 HP 3500 RPM 3Ph, frame 284/6	_	
	40020032	40 HP 3500 RPM 3Ph, frame 324/6		
	40020034	50 HP 3500 RPM 3Ph, frame 324/6		
	03010028	Intermediate coupling for 3 and 5 HP		
2	03010018	Intermediate coupling for 7.5 and 15 HP	1	
	03010051	Intermediate coupling for 20 HP		
	03010020	Intermediate coupling for 25 to 50 HP	1	
3	03090042	Volute case	1	
	03140035l	Impeller IA3 - 3 HP - 4 Ø7.50" (shaft 7/8")		
	03140035J	Impeller IA3 - 5 HP - 4 Ø8.40" (shaft 7/8")		
	03140035H	Impeller IA3 - 7.5 HP - 4 Ø9" (shaft 7/8")		
	03140035	Impeller IA3 - 15 HP - 2 Ø6.938 (shaft 7/8")		
4	03140035B	Impeller IA3 - 20 HP - 2 Ø6.938 (shaft 7/8")	1	
		Impeller IA3 - 25 HP - 2 Ø7.50 (shaft 1¼")		
	03140035D	Impeller IA3 - 30 HP - 2 Ø8 (shaft 11/4")		
	40020035E	Impeller IA3 - 40 HP - 2 Ø8.75 (shaft 1¼")		
	40020035F	Impeller IA3 - 50 HP - 2 Ø9 (shaft 1¼")		
5	30400808	Shaft sleeve for 3 to 15 HP	1	
Ĵ	30400812	Shaft sleeve for 20 to 50 HP	ļ.	
6	92010029J	O-ring shaft sleeve for 3 to 15 HP	1	
	92010029M	O-ring shaft sleeve for 20 to 50 HP		
7	92010014	Sliger, for 3 to 15 HP	1	
	92010016	Slinger, for 20 to 50 HP		
8	31030131	Mecanical seal for 3 to 15 HP	1	
	31030133	Mecanical seal for 20 to 50 HP		
9	92010033	O-Ring	1	
10	91010345	Impeller's screw 3/8" x 1" SS for 3 to 15 HP	1	
10	91010351	Impeller's screw 1/2" x 1½" SS for 20 to 50 HP	·	
11	91010061	Lock washer 3/8" SS for 3 to 15 HP	1	
	91010062	Lock washer 1/2" SS for 20 to 50 HP	Ľ.	
12	30400418	Impeller washer for 3 to 15 HP	1	
	30400416	Impeller washer for 20 to 50 HP	·	
13	30400631	Shaft key 3/16" for 3 to 15 HP	1	
15	30400633	Shaft key 1/4" for 20 to 50 HP		
14	91010303	Stud 3/8" x 1½"	8	
15	91010413	Hex nut 3/8"	8	
16	91010012	Lock washer 3/8"	8	
	91010242	Cap screw 3/8" x 1" for 3 and 5 HP		
17	91010263	Cap screw 1/2" x 1½" for 7.5 to 20 HP	4	
	91010282	Cap screw 5/8" x 1½" for 25 to 50 HP		
	91010012	Lock washer 3/8" for 3 and 5 HP		
18	91010014	Lock washer 1/2" for 7.5 to 20 HP	4	
-	91010015	Lock washer 5/8" for 25 to 50 HP		
19a	93010143	Pipe plug 1/4"	3	
19b	93010142	Pipe plug 1/2"	1	

To order any spare part please supply the model and serial number as shown on the nameplate, and the description and part number as shown in the parts list.


▶ IA3H

Item	Part No.	Description	Qty.	
	40020029	30 HP, 3500 RPM, 3 ph, frame 284/6 JM		
	40020032	40 HP, 3500 RPM, 3 ph, frame 324/6 JM		
1	40020034	50 HP, 3500 RPM, 3 ph, frame 324/6 JM	1	
	40020036	60 HP, 3500 RPM, 3 ph, frame 364/5 JM		
	40020038	75 HP, 3500 RPM, 3 ph, frame 364/5 JM		
2	03010020	Intermediate coupling	1	
3	03090042B	Volute case	1	
	03140066	Impeller IA3H for 30 HP, Ø 6.875"		
	03140066B	Impeller IA3H for 40 HP, Ø 7.50"		
4	03140066C	Impeller IA3H for 50 HP, Ø 7.94"	1	
	03140066D	Impeller IA3H for 60 HP, Ø 8.50"		
	03140066E	Impeller IA3H for 75 HP, Ø 9.00"		
5	030400812	Shaft sleeve	1	
6	92010029M	O-Ring shaft sleeve	1	
7	92010016	Slinger	1	
8	31030133	Mechanical seal	1	
9	92010033	O-Ring	1	
10	91010351	Impeller screw	1	
11	91010062	Lock washer, 1/2" SS	1	
12	30400416	Impeller washer	1	
13	30400633	Shaft key	1	
14	91010303	Stud 3/8-16x 1-1/2"	8	
15	91010413	Hex nut 3/8"	8	
16	91010012	Lock washer 3/8"	8	
17	91010282	Cap screw, 5/8 x 1-1/2"	4	
18	91010015	Lock washer 5/8"	4	
19a	93010142	Pipe plug 1/4" NPT	3	
19b	93010143	Pipe plug 1/2" NPT	1	

▶ IA3BJM

Item	Part No.	Description	Qty.
	40020021	Motor 15 HP 1800 RPM 3ph frame 254/6JM	
	40020024	Motor 20 HP 1800 RPM 3ph frame 254/6JM	
1	40020027	Motor 25 HP 1800 RPM 3ph frame 284/6JM	1
	40020030	Motor 30 HP 1800 RPM 3ph frame 284/6JM	
	40020033	Motor 40 HP 1800 RPM 3ph frame 324/6JM	
2	03010039	Intermediate coupling 8.5", for 15 & 20 HP	1
2	03010040	Intermediate coupling 12.5", for 25 to 40 HP	
3	03090069	Volute case	1
	03140133	Impeller for 15 HP (Ø 10.188")	
	3140133B	Impeller for 20 HP (Ø 11.125")	
4	3140133C	Impeller for 25 HP (Ø 11.812")	1
	3140133D	Impeller for 30 HP (Ø 12.437")	
	3140133F	Impeller for 40 HP (Ø 13.50")	
5	30400815	Shaft sleeve SS	1
6	92010016	Slinger	1
7	31030133	Mechanical seal	1
8	92010162	Body gasket	1
9	91010351	Cap screw 1/2 x 1-1/2" SS	1
10	91010062	Lock washer 1/2" SS	1
11	30400416	Impeller washer	1
12	30400639	Shaft key	1
13	91010282	Cap screw 5/8" x 1-1/2"	12
14	91010015	Lock washer 5/8"	24
15	91010263	Cap screw 1/2" x 1-1/2" for 15 & 20 HP	1
15	91010282	Cap screw 5/8" x 1-1/2" for 25 to 40 HP	4
16	91010014	Lock washer 1/2" for 15 & 20 HP	4
16	91010015	Lock washer 5/8" for 25 to 40 HP	4
17	91010244	Cap screw 3/8 x 1-1/2"	4
18	91010012	Lock washer 3/8"	4
19	03060004	Discharge flange 3"	1
20	03060006	Suction flange 4"	1
21	92010155	Flange gasket 3"	1
22	92010156	Flange gasket 4"	1
23	91010285	Cap screw 5/8" x 3"	4
24	91010416	Hex nut 5/8"	4
25	91010283	Cap screw 5/8" x 2"	8
26	03190010B	Wear plate	1
27	92010191	Wear plate gasket	1
28	31010008	Retaining ring	1
29	30400316	Wear ring	1
30	93010142	Pipe plug 1/2"	4
30	93010142	Pripe plug 1/2"	4






29


TYPICAL EXPLODED VIEW CENTRIFUGAL PUMP

MODEL * IA2½H



► IA21/2H

ltem	Part No.	Description	Qty.	
1	40020032	40 HP, 3500 RPM, 3ph, frame 324/6 JM		
	40020034	50 HP, 3500 RPM, 3ph, frame 324/6 JM		
	40020036	60 HP, 3500 RPM, 3ph, frame 364/5 JM	1	
	40020038	75 HP, 3500 RPM, 3ph, frame 364/5 JM		
	40020040	100 HP, 3500 RPM, 3ph, frame 405 TCZ		
2	03010065	Intemediate coupling		
3	03090094	Volute case		
4	03140142	Impeller IA2½H for 100 HP, diam. 10.197" (shaft 1-¼"Ø)		
	03140142B	Impeller IA21/2H for 75 HP, diam. 9.842" (shaft 1-1/4"Ø)		
	03140142C	Impeller IA2½H for 60 HP, diam. 9.055" (shaft 1-¼"Ø)	1	
	03140142D	Impeller IA21/2H for 50 HP, diam. 8.464" (shaft 1-1/4"Ø)		
	03140142E	Impeller IA2½H for 40 HP, diam. 7.875" (shaft 1-¼"Ø)		
5	30400838	Shaft sleeve		
6	92010016	Slinger	1	
7	31030411	Mechanical seal		
8	92010090	O-ring		
9	91010351	Cap screw 1/2" x 1-1/2" SS	1	
10	91010062	Lock washer 1/2" SS	1	
11	30400416	Impeller washer	1	
12	30400633	Shaft key 1/4"	1	
13	91010310	Stud 1/2" x 2"	8	
14	91010014	Lock washer 1/2"	8	
15	91010415	Hex. nut 1/2"	8	
16	91010282	Cap screw 5/8" x 1-1/2"	4	
17	91010015	Lock washer 5/8"	16	
18	03060013	Discharge flange 2-1/2"		
19	03060006	Suction flange 4"		
20	92010175	Flange gasket 2-1/2"	1	
21	92010156	Flange gasket 4"		
22	91010285	Cap screw 5/8" x 3"		
23	91010416	Hex. nut 5/8"	12	
24	91010283	Cap screw 5/8" x 2"	8	
25	93010143	Pipe plug 1/4" NPT	2	



North America: 866 777 6060



Risk of electric shock. Always disconnect the pump from the power source before handling inspections or repairs.

PROBLEM	PROBABLE CAUSE	CHECK
A) The country of the	Air leak in the suction system.	 Threaded joints in the suction tightness. Gaskets for no wear. The mechanical seal for leaks. The drain plug has leaks. The vacuum gauge may be leaking.
A) The pump does not prime, the vacuum gauge indicates a lower reading than normal.	2. Insufficient liquid in the pump casing.	- That the pump's body is filled with water.
lower reading than normal.	3. Low operating speed.	- The motor speed (RPM).
	4. Bound pump.	- Impeller rotates freely Internal parts are clean.
	5. Mechanical defect.	- That the internal parts are not worn.
B) The pump does not prime, the vacuum gauge reading indicates higher than normal.	1. Pipe clogged suction.	- The suction line is clean.
C) The pump priming good vacuum gauge reading is normal, the manometer	1. The pump speed is very low.	- The voltage is correct.
indicates a lower pressure than normal.	2. Mechanical defects.	- The internal parts for wear.
D) The pump priming good vacuum gauge reading is	1. Discharge obstructed.	- The discharge is clear of obstructions.
almost normal, reading the manometer is greater.		- That the discharge valves operate correctly.
E) The pump loses its priming	1. suction dynamic level too high.	- When the pump is operating, never lacks water in the suction.
during operation, vacuum gauge reading drops to zero.	2. The pump is sucking air.	 For leaks in suction piping, flanges and gaskets. That there is no vortex effect at the end of the suction, this lack of water.
	1. Pump base is loose.	- That screws are tight at the base There are no cracks in the base.
OM	3	- The dynamic level is not too high - That the pumping capacity is not too much.
F) The pump priming pumps well and satisfactorily but noisy.	2. Cavitation.	- The pump is operating in the range of NPSHF - If reducing flow makes the noise gone, then the problem is in the point above; partially close the discharge valve.
SPRINGER	3. Bearings.	- The bearings for wear That there is oil in the deposit.
	4. Vibration.	 The impeller does not have any foreign material. The pump is operating in the range. That the alignment is correct.
	1. Low Voltage.	- The voltage is correct.
G) Motor overload.	2. Overload.	 The amperage of the plate is not exceeded. There is no foreign material that may force the impeller. That the motor is suitable for the pump.

NOTE: Barmesa Pumps assumes no responsibility for damage or injury due to disassembly in the field. Disassembly of the pumps or supplied accessories other than at Barmesa Pumps or its authorized service centers, automatically voids warranty.

BARMESA PUMPS FACTORY WARRANTY

Barmesa Pumps warrants that products of our manufacture will be free of defects in material and workmanship under normal use and service for 18 months from date of manufacture or 12 months from installation date whichever occurs first. This warranty gives you specific legal rights, which vary from state to state.

This warranty is a limited warranty, and no warranty related claims of any nature whatsoever shall be made against Barmesa Pumps, until the ultimate consumer or his/her successor notifies us in writing of the defect and delivers the product and/or defective part(s) freight prepaid to our factory or nearest authorized service station as instructed by Barmesa Pumps. THERE SHALL BE NO FURTHER LIABILITY, WHETHER BASED ON WARRANTY, NEGLIGENCE OR OTHERWISE. PRODUCT SHALL BE EITHER REPLACED OR REPAIRED AT THE ELECTION OF BARMESA PUMPS. Guarantees relating to performance specifications provided in addition to the foregoing material and workmanship warranties on a product manufactured by Barmesa Pumps, if any, are subject to possible factory testing. Any additional guarantees, in the nature of certified performance specifications or time frame must be in writing and such writing must be signed by our authorized factory manager at time of order placement and/or at time of quotation. Due to inaccuracies in field testing and should a conflict arises between the results of field testing conducted by or for the user, Barmesa Pumps reserves the right to have the product returned to our factory for additional testing.

This warranty shall not apply when damage is caused by (1) improper installation, (2) improper voltage, (3) lightning, (4) excessive sand or other abrasive material, (5) corrosion build-up due to excessive chemical content or (6) uncontrollable acts of god. Any modification of the original equipment will also void the warranty. We will not be responsible for loss, damage or labor cost due to interruption of service caused by defective pumps, parts or systems. Barmesa Pumps will not accept charges incurred by others without our prior written approval.

This warranty is void if our inspection reveals the product was used in a manner inconsistent with normal industry practice and/or our specific recommendations. The purchaser is responsible for communication of all necessary information regarding the application and use of the product. UNDER NO CIRCUMSTANCES WILL WE BE RESPONSIBLE FOR ANY OTHER DIRECT OR CONSEQUENTIAL DAMAGES, INCLUDING BUT NOT LIMITED TO TRAVEL EXPENSES, CONTRACTOR FEES, UNAUTHORIZED REPAIR SHOP EXPENSES, LOST PROFITS, LOST INCOME, LABOR CHARGES, DELAYS IN PRODUCTION, IDLE PRODUCTION, WHICH DAMAGES ARE CAUSED BY ANY DEFECTS IN MATERIAL AND/OR WORKMANSHIP AND/OR DAMAGE OR DELAYS IN SHIPMENT. THIS WARRANTY IS EXPRESSLY IN LIEU OF ANY OTHER EXPRESS OR IMPLIED WARRANTY. No rights extended under this warranty shall be assigned to any other person, whether by operation of law or otherwise, without our prior written approval.

IMPORTANT!

If you have a claim under the provision of the warranty, contact Barmesa Pumps or your authorized Barmesa Pumps Distributor:
warranty@barmesapumps.com
www.barmesapumps.com



North America: 866 777 6060 Int'l: +1 267 404 2910 Springer Pumps Springer Parts www.springerpumps.com www.springerparts.com